

IEC 61850 Certificate - IEC 61850 Certificate #2218

MiCOM C264 [Schneider Electric]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101852-MOC/INC 13-1306
61850 Edition:	Edition 1	Certificate Hash:	DD7107B019E61E158E6F053A06C6F2 FE73686C2354B7D0573E17A204110D3 E99
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric	Vendor Artifact Hash:	
Address:	Avenue de Figuieres 34975 Lattes France	Umbrella Organization:	Schneider Electric
Product:	MiCOM C264	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	B8.16G	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/07/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-1306_SchneiderElectric_MiCOM_C264_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

13-1306_SchneiderElectric_MiCOM_C264_Certificate.pdf	292 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------