

IEC 61850 Certificate - IEC 61850 Certificate #2220

MFP-H1SA [Mitsubishi Electric Corporation]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74102438-MOC/INC 13-1480
61850 Edition:	Edition 1	Certificate Hash:	1342325F2C9F6F651E6E22A6E7A02D B81B02F01CE33F454DC4EB9E1D4A4 BB801
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	1-5-8 Takatsukadai, Nishi-ku Kobe 651-2271 Japan	Umbrella Organization:	
Product:	MFP-H1SA	Optional Reservation Test:	No
HW Version:	SCHEME No. 637PSA	Serial Number:	
SW Version:	JQ41 B/JQ42 B/HL05/HL06 A/HL08 C	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/07/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-1480_Mitsubishi_MFP-H1SA_Certificate.pdf added

Files

13-1480_Mitsubishi_MFP-H1SA_Certificate.pdf	301 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------