

IEC 61850 Certificate - IEC 61850 Certificate #2223

SEL-3530 [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101693-MOC/INC 13-2029
61850 Edition:	Edition 1	Certificate Hash:	0DFD74C6FB70AAB6637F1791678EDA 81E2DE63B50B74382D2BA4DC075779 1308
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Umbrella Organization:	
Product:	SEL-3530	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R122	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/07/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	ABB Switzerland Ltd. (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-2029_SEL_3530_Server_Certificate.pdf added

Files

13-2029_SEL_3530_Server_Certificate.pdf	273 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------