

IEC 61850 Certificate - IEC 61850 Certificate #2226

MP3-3 L2 [3AO-MP3]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104415-MOC/INC 13-2118
61850 Edition:	Edition 1	Certificate Hash:	C7C4DAFA8A6DED93B84165BB6A2F5 4B3B0539BFFD5F532A13BA725997500 1EC7
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	3AO-MP3	Vendor Artifact Hash:	
Address:	2nd Kabelnaya Str., 2, Build. 3, Office 79-82, 111024, Moscow Russia	Umbrella Organization:	
Product:	MP3-3 L2	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.015	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/07/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-2118_3AO-MP3_MP3-3_L2_L1_AUV_D_DZSH_DZT_Certificate.pdf added

Files

13-2118_3AO-MP3_MP3-3_L2_L1_AUV_D_DZSH_DZT_Certificate.pdf 47 KB

07/08/2021

Herbert Falk