

IEC 61850 Certificate - IEC 61850 Certificate #2227

MiCOM P746 [Schneider Electric]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104410-MOC/INC 13-2121
61850 Edition:	Edition 1	Certificate Hash:	F18932B99E513C711D02995239CB9A C77CD2984C1052F886E84EB98E05BA A99E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier 92500 Rueil Malmaison France	Umbrella Organization:	Schneider Electric
Product:	MiCOM P746	Optional Reservation Test:	No
HW Version:	Suffix K/SER No. 36201551/02/13	Serial Number:	
SW Version:	A0B	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/07/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-2121_SchneiderElectric_P746_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

13-2121_SchneiderElectric_P746_Certificate.pdf	319 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------