

IEC 61850 Certificate - IEC 61850 Certificate #2231

VAMP257 [Schneider Electric - Vamp Oy]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104491-MOC/INC 13-2744
61850 Edition:	Edition 1	Certificate Hash:	E192CE2EAC3978F7C378CFD306E286 6D108643C4DDD723846369E7A07237 A30A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric - Vamp Oy	Vendor Artifact Hash:	
Address:	Yrittajankatu, 15 P.O. Box 810 65101 - Vaasa Finland	Umbrella Organization:	Schneider Electric
Product:	VAMP257	Optional Reservation Test:	No
HW Version:	Serial Number: 034852	Serial Number:	
SW Version:	10.131	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/07/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 13-2744_VAMP257_Certificate.pdf added

#2 - 07/09/2021 09:17 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

13-2744_VAMP257_Certificate.pdf	181 KB	07/08/2021	Herbert Falk
---------------------------------	--------	------------	--------------