

IEC 61850 Certificate - IEC 61850 Certificate #2233

Areva MiCOM P242 [Areva T&D UK Ltd.]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6242.803
61850 Edition:	Edition 1	Certificate Hash:	74F91178DB0090644484CC6CC5BD20 482596698F31890B34FA2A98C522B65 78E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Areva T&D UK Ltd.	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford, ST17 4LX United Kingdom	Umbrella Organization:	
Product:	Areva MiCOM P242	Optional Reservation Test:	No
HW Version:	K	Serial Number:	
SW Version:	C6.2	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/10/2015		
Standards Tested:	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 50745.6242.803_AREVA_P24257K_Certificate.pdf added

#2 - 08/04/2021 09:37 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6242.803_AREVA_P24257K_Certificate.pdf	222 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------