

IEC 61850 Certificate - IEC 61850 Certificate #2234

PCS-931 [NR Electric Co., Ltd.]

07/08/2021 04:29 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 15 08 61589 047
61850 Edition:	Edition 2	Certificate Hash:	265D3C4FF3446BFE22DB8A55B65944 6FD5F8B3EBECF2D121696A4516DA11 DE7D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NR Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	69 Suyuan Avenue, Jiangning 211106, Nanjing, People's Republic of China	Umbrella Organization:	
Product:	PCS-931	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.00	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:29 PM - Herbert Falk

- File 15-ZE 15 08 61589 047-NR Electric_PCS-931_IEC61850Ed2-Server added

Files

15-ZE 15 08 61589 047-NR Electric_PCS-931_IEC61850Ed2-Server.pdf 47 MB

07/08/2021

Herbert Falk