

# IEC 61850 Certificate - IEC 61850 Certificate #2237

## SEL-487B [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:30 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74104508-MOC/INC 13-3113
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	D8F59CBD0F5E32DF0E8E424081B16C E9C5EBD40DDB156C5DBB44CD58BF 478194
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schweitzer Engineering Laboratories, Inc.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	2350 NE Hopkins Court Pullman, WA 99163-5602 USA	<b>Umbrella Organization:</b>	
<b>Product:</b>	SEL-487B	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	R307	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/10/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-3113\_SEL-487B\_Certificate.pdf added

### Files

13-3113_SEL-487B_Certificate.pdf	2.35 MB	07/08/2021	Herbert Falk
----------------------------------	---------	------------	--------------