

IEC 61850 Certificate - IEC 61850 Certificate #2240

GRE130 [Toshiba Corporation]

07/08/2021 04:30 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104728-MOC/INC 13-3226
61850 Edition:	Edition 1	Certificate Hash:	E86296A33762A7A7188677B8F645454 1084BAAD13FEEE1F7B079A93E3E2F2 358
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Toshiba Corporation	Vendor Artifact Hash:	
Address:	Power Systems Protection and Control Fuchu-Complex 1, Toshiba-Cho Fuchu-shi, Tokyo, 183-8511 Japan	Umbrella Organization:	
Product:	GRE130	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	GS1EM1-03-C	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-3226_TOSHIBA_GRE130_Certificate.pdf added

Files

13-3226_TOSHIBA_GRE130_Certificate.pdf	158 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------