

IEC 61850 Certificate - IEC 61850 Certificate #2242

P40 Agile P14DZ [ALSTOM Grid UK LTD]

07/08/2021 04:30 PM - Herbert Falk

| | | | |
|-------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|--------------------------------------------------------------------------|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 74104759-MOC/INC 13-3261 |
| 61850 Edition: | Edition 1 | Certificate Hash: | B7EB8F37555DCE6E84494CFD154B7E C67455B3D5E1D87D04D59F050EC40A B1D3 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | ALSTOM Grid UK LTD | Vendor Artifact Hash: | |
| Address: | St. Leonards Avenue Stafford ST17 4LX United Kingdom | Umbrella Organization: | |
| Product: | P40 Agile P14DZ | Optional Reservation Test: | No |
| HW Version: | A | Serial Number: | |
| SW Version: | 50H | Publisher Legacy Variants: | |
| Key Words: | | Publisher Preferred Rates: | |
| Test Procedure Version: | 2.3 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | kathy.ellis | Subscriber Preferred Variants: | |
| Approval Date: | 09/10/2015 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-3261_Alstom_Grid_P14DZ_P14DB_P14DG_P14DL_P14NB_P14NZ_Cert added

Files

13-3261_Alstom_Grid_P14DZ_P14DB_P14DG_P14DL_P14NB_P14NZ_Certificate.pdf 07/08/2021

Herbert Falk