

IEC 61850 Certificate - IEC 61850 Certificate #2243

IRX [ZIV GRID Automation S.L.]

07/08/2021 04:30 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101841-MOC/INC 13-3317
61850 Edition:	Edition 1	Certificate Hash:	95083F6E82AE61E1391DC953D743382 699854679202F37E83DC5883C417E69 6E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ZIV GRID Automation S.L.	Vendor Artifact Hash:	
Address:	Parque Tecnológico, Edificio 210-48170 Zamudio, Bizkaia Spain	Umbrella Organization:	
Product:	IRX	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	6.5B	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-3317_ZIV_IRX_Certificate.pdf added

Files

13-3317_ZIV_IRX_Certificate.pdf	2.08 MB	07/08/2021	Herbert Falk
---------------------------------	---------	------------	--------------