

IEC 61850 Certificate - IEC 61850 Certificate #2246

C264 [Alstom Grid]

07/08/2021 04:30 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104760-MOC/INC 13-3584 rev2
61850 Edition:	Edition 1	Certificate Hash:	B357AB968938C4097879FA3E429A12E 37C479033CEBC2B34E239E6D947E37 932
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Alstom Grid	Vendor Artifact Hash:	
Address:	Parc Eureka - 81, rue Euclide 34000 Montpellier France	Umbrella Organization:	
Product:	C264	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	5.1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-3584_Alstom_C264_Certificate_rev2.pdf added

Files

13-3584_Alstom_C264_Certificate_rev2.pdf	2.33 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------