

IEC 61850 Certificate - IEC 61850 Certificate #2247

SEL-411L [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:30 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104508-MOC/INC 13-3642
61850 Edition:	Edition 1	Certificate Hash:	2D4AF3D27205C2A4F66FF091CA090E 98C34498C1834BF7BC8900BD940773 436F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-411L	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R111	Publisher Legacy Variants:	
Key Words:	Differential, Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-3642_SEL-411L_Certificate.pdf added

Files

13-3642_SEL-411L_Certificate.pdf	2.36 MB	07/08/2021	Herbert Falk
----------------------------------	---------	------------	--------------