

IEC 61850 Certificate - IEC 61850 Certificate #2249

REF615 [ABB Oy]

07/08/2021 04:30 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74102147-MOC/INC 13-4263
61850 Edition:	Edition 1	Certificate Hash:	C3F7033BAF8EB7FF14148B3B37F551 D42B8A5BCAC3FEC5B31D9A5FA79F3 82BFF
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB Oy	Vendor Artifact Hash:	
Address:	Distribution Automation Muottitie 2 A FI-65101 Vaasa Finland	Umbrella Organization:	
Product:	REF615	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	5.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-4263_ABB_REF615_RED615_REM615_RET615_REU615_REV615_Certif added

Files

13-4263_ABB_REF615_RED615_REM615_RET615_REU615_REV615_Certif.pdf 07/08/2021

Herbert Falk