

IEC 61850 Certificate - IEC 61850 Certificate #2250

Siprotec V4 7SJ66 [Siemens A.G., IC SG EA]

07/08/2021 04:30 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74105246-MOC/INC 13-4265
61850 Edition:	Edition 1	Certificate Hash:	6389DDD3BDC22A28F5E3E50AB47432 C1DE68EC6615C1F9E9117B5FB01497 3886
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens A.G., IC SG EA	Vendor Artifact Hash:	
Address:	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	Umbrella Organization:	
Product:	Siprotec V4 7SJ66	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	04.00	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-4265_SIEMENS_7SJ66_Certificate.pdf added

Files

13-4265_SIEMENS_7SJ66_Certificate.pdf

2.22 MB

07/08/2021

Herbert Falk