IEC 61850 Certificate - IEC 61850 Certificate #2251

DS Agile GTW [Alstom Grid]

07/08/2021 04:30 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	74104760-MOC/INC 13-4312
61850 Tested Aspects:	Server	**Certificate Hash:**	37651C422103C0C1222A80F9BDD8E244B27EEE1B2201F4C9748EB2BF9187F34A
Company:	Alstom Grid	**Vendor Artifact File Name:**	
Address:	Parc Eureka - 81, rue Euclide 34000 - Montpellier France	**Vendor Artifact Hash:**	
Product:	DS Agile GTW	**Umbrella Organization:**	
HW Version:	Advantech UNO-3074 w/Win XP	**Optional Reservation Test:**	No
SW Version:	7.2.0	**Serial Number:**	
Key Words:		**Publisher Legacy Variants:**	
Test Procedure Version:	2.3	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	09/11/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-4312_AlstomGrid_DS_Agile_GTW_Certificate.pdf added

Files

13-4312_AlstomGrid_DS_Agile_GTW_Certificate.pdf	2.59 MB	07/08/2021	Herbert Falk