

# IEC 61850 Certificate - IEC 61850 Certificate #2252

## MiCOM P40 Agile P341 [ALSTOM Grid UK LTD]

07/08/2021 04:30 PM - Herbert Falk

|                                     |   |                                       |  |
|-------------------------------------|---|---------------------------------------|--|
| <b>Status:</b>                      | Approved  | <b>Test Document:</b>                 |  |
| <b>Priority:</b>                    | Normal  | <b>Certificate Name:</b>              | 74105340-MOC/INC 13-4341   |
| <b>61850 Edition:</b>               | Edition 1   | <b>Certificate Hash:</b>              | 30320B214E88AB6ACD2F77FD53112D<br>4D8F2DAFE7D978A2947EE7026AA525<br>3995 |
| <b>61850 Tested Aspects:</b>        | Server  | <b>Vendor Artifact File Name:</b>     |  |
| <b>Company:</b>                     | ALSTOM Grid UK LTD  | <b>Vendor Artifact Hash:</b>          |  |
| <b>Address:</b>                     | St. Leonards Avenue<br>Stafford ST17 4LX<br>United Kingdom  | <b>Umbrella Organization:</b>         |  |
| <b>Product:</b>                     | MiCOM P40 Agile P341  | <b>Optional Reservation Test:</b>     | No   |
| <b>HW Version:</b>                  | P   | <b>Serial Number:</b>                 |  |
| <b>SW Version:</b>                  | 72  | <b>Publisher Legacy Variants:</b>     |  |
| <b>Key Words:</b>                   | Protection, Relay   | <b>Publisher Preferred Rates:</b>     |  |
| <b>Test Procedure Version:</b>      | 2.3   | <b>Publisher Preferred Variants:</b>  |  |
| <b>IEC 61850 Blocks Certified:</b>  | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | <b>Subscriber Legacy Variants:</b>    |  |
| <b>Certificate/Result Reviewer:</b> | kathy.ellis   | <b>Subscriber Preferred Variants:</b> |  |
| <b>Approval Date:</b>               | 09/11/2015  | <b>Subscriber Preferred Rates:</b>    |  |
| <b>Standards Tested:</b>            | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1  |                                       |  |
| <b>Current Test Lab Name:</b>       | DNV Netherlands (A)   |                                       |  |

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:30 PM - Herbert Falk

- File 13-4341\_AlstomGrid\_P341\_Certificate.pdf added

### Files

|   |         |            |              |
|---|---------|------------|--------------|
| 13-4341_AlstomGrid_P341_Certificate.pdf | 2.57 MB | 07/08/2021 | Herbert Falk |
|---|---------|------------|--------------|