

IEC 61850 Certificate - IEC 61850 Certificate #2258

SEL-651R Recloser Control [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:31 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74102139-MOC/INC 14-0133
61850 Edition:	Edition 1	Certificate Hash:	8436E1C3104FB5A99BEB81A2CD8349 D2C4A4CA4724DE80418DAC3FA1E74 03E4E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-651R Recloser Control	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R404	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:31 PM - Herbert Falk

- File 14-0133_SEL_651R_Certificate.pdf added

Files

14-0133_SEL_651R_Certificate.pdf	2.61 MB	07/08/2021	Herbert Falk
----------------------------------	---------	------------	--------------