

IEC 61850 Certificate - IEC 61850 Certificate #2259

P60 Agile P163 [ALSTOM Grid UK LTD]

07/08/2021 04:31 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104125-OPE/INC 14-0394
61850 Edition:	Edition 1	Certificate Hash:	47320D06C3D5E92B41FBAB8D38019D 27569765155679938A7D5D89088146A 164
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ALSTOM Grid UK LTD	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford ST17 4LX United Kingdom	Umbrella Organization:	
Product:	P60 Agile P163	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	FW1.11.1	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:31 PM - Herbert Falk

- File 14-0394_AlstomGrid_P163_Certificate.pdf added

Files

14-0394_AlstomGrid_P163_Certificate.pdf	2.45 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------