

IEC 61850 Certificate - IEC 61850 Certificate #2260

MiCOM P40 Agile P747 [ALSTOM Grid UK LTD]

07/08/2021 04:31 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74105595-OPE/INC 14-0459
61850 Edition:	Edition 1	Certificate Hash:	B18105D57DB0B69DD942907033AB37 1574F307CEF9E49624846691BCE41F EF7B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ALSTOM Grid UK LTD	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford ST17 4LX United Kingdom	Umbrella Organization:	
Product:	MiCOM P40 Agile P747	Optional Reservation Test:	No
HW Version:	K	Serial Number:	
SW Version:	03	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:31 PM - Herbert Falk

- File 14-0459_AlstomGrid_P747_Certificate.pdf added

Files

14-0459_AlstomGrid_P747_Certificate.pdf	2.55 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------