

IEC 61850 Certificate - IEC 61850 Certificate #2267

SICAM P855 7KG855 [Siemens A.G., IC SG EA]

07/08/2021 04:31 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101558-OPE/INC 14-0531
61850 Edition:	Edition 1	Certificate Hash:	3E480121A9CC9C96D5112A577C2922 B4EB038BCCFA5346991364B0D57BD7 B223
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens A.G., IC SG EA	Vendor Artifact Hash:	
Address:	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	Umbrella Organization:	
Product:	SICAM P855 7KG855	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.10	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:31 PM - Herbert Falk

- File 14-0531_Siemens_SICAM_7KG855_7KG850_Certificate.pdf added

Files

14-0531_Siemens_SICAM_7KG855_7KG850_Certificate.pdf	2.34 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------