

IEC 61850 Certificate - IEC 61850 Certificate #2268

T5502 RTU [GE Power Conversion]

07/08/2021 04:31 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104912-OPE/INC 14-0605
61850 Edition:	Edition 1	Certificate Hash:	C2B131ADDFED5F72EC785BD016308 D71C09183C8FE68788C2AAA28E4EA BD5200
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Power Conversion	Vendor Artifact Hash:	
Address:	Boughton Road Rugby, Warwickshire CV21 1BU United Kingdom	Umbrella Organization:	
Product:	T5502 RTU	Optional Reservation Test:	No
HW Version:	GE T5502 Processor	Serial Number:	
SW Version:	4.15, Revision 165	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:31 PM - Herbert Falk

- File 14-0605_GE_UK_T5502_Certificate.pdf added

Files

14-0605_GE_UK_T5502_Certificate.pdf	2.67 MB	07/08/2021	Herbert Falk
-------------------------------------	---------	------------	--------------