

IEC 61850 Certificate - IEC 61850 Certificate #2270

SMRT36 [Megger]

07/08/2021 04:31 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74105120-OPE/INC 14-0948
61850 Edition:	Edition 1	Certificate Hash:	EA22981C6CC073F9F70AF94CC1CA0 E463FE48CA73735659DB93C6254DFC 79170
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Megger	Vendor Artifact Hash:	
Address:	4271 Bronze Way Dallas, TX 75237-1088 USA	Umbrella Organization:	
Product:	SMRT36	Optional Reservation Test:	No
HW Version:	GenRev: 2.52	Serial Number:	
SW Version:	1.260	Publisher Legacy Variants:	
Key Words:	Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:31 PM - Herbert Falk

- File 14-0948_Megger_SMRT36_Certificate.pdf added

Files

14-0948_Megger_SMRT36_Certificate.pdf	2.4 MB	07/08/2021	Herbert Falk
---------------------------------------	--------	------------	--------------