

IEC 61850 Certificate - IEC 61850 Certificate #2271

ZLV-G [ZIV GRID Automation S.L.]

07/08/2021 04:31 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	12131046-OPE/INC 14-1086
61850 Edition:	Edition 1	Certificate Hash:	42BD5A8743DF774AF3511081ED9D9F ADB52FA43C3C3B674C473838B46106 1C92
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ZIV GRID Automation S.L.	Vendor Artifact Hash:	
Address:	Parque Tecnológico, 210 48170 Zamudio, Bizkaia Spain	Umbrella Organization:	
Product:	ZLV-G	Optional Reservation Test:	No
HW Version:	8ZLV-G3F-26S3C6QML	Serial Number:	
SW Version:	7.4R	Publisher Legacy Variants:	
Key Words:	Distance, Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:31 PM - Herbert Falk

- File 14-1086_ZIV_ZLV-G_Certificate.pdf added

Files

14-1086_ZIV_ZLV-G_Certificate.pdf	2.78 MB	07/08/2021	Herbert Falk
-----------------------------------	---------	------------	--------------