

IEC 61850 Certificate - IEC 61850 Certificate #2276

SMRT410 [Megger]

07/08/2021 04:32 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74105120-OPE/INC 14-1249
61850 Edition:	Edition 1	Certificate Hash:	B8DBC81546BA2C5B18B2CB65C77B6 D94B02139B9263126AEF1ED8B8ED0A E689C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Megger	Vendor Artifact Hash:	
Address:	4271 Bronze Way Dallas, TX 75237-1088 USA	Umbrella Organization:	
Product:	SMRT410	Optional Reservation Test:	No
HW Version:	GenRev: 2.52	Serial Number:	
SW Version:	1.260	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:32 PM - Herbert Falk

- File 14-1249_Megger_SMRT410_Certificate.pdf added

Files

14-1249_Megger_SMRT410_Certificate.pdf	2.32 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------