

IEC 61850 Certificate - IEC 61850 Certificate #2277

PRS-7367-D [CYG SUNRI Co., Ltd.]

07/08/2021 04:32 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74105511-OPE/INC 14-1284
61850 Edition:	Edition 1	Certificate Hash:	1EA907D0FF5AC1E50FB42E3D4E645F C4A9A0DB7A62AF0B63AA25F4F245FE 462A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	CYG SUNRI Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 13, Keji North 1st Road, North Area of Hi-Tech Industrial Park, Nanshan District, Shenzhen518057, China	Umbrella Organization:	
Product:	PRS-7367-D	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	3.10	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:32 PM - Herbert Falk

- File 14-1284_CYGSUNRI_PRS7367D_Certificate.pdf added

Files

14-1284_CYGSUNRI_PRS7367D_Certificate.pdf	2.73 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------