

# IEC 61850 Certificate - IEC 61850 Certificate #2279

## Shark 200 Multifunction Meter [Electro Industries/GaugeTech]

07/08/2021 04:32 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	74105822-OPE/INC 14-1413
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	A6A2DF38A5A1DF9637F4B3217C0FF7 63E5B069FAC2030A3A79B0A48181568 46B
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Electro Industries/GaugeTech	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	1800 Shames Drive Westbury, NY 11590-1730 USA	<b>Umbrella Organization:</b>	
<b>Product:</b>	Shark 200 Multifunction Meter	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	INP300S Rev K	<b>Serial Number:</b>	
<b>SW Version:</b>	3.35	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Meter	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/11/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:32 PM - Herbert Falk

- File 14-1413\_ElectroIndustries\_Shark200\_Certificate.pdf added

### Files

14-1413_ElectroIndustries_Shark200_Certificate.pdf	2.51 MB	07/08/2021	Herbert Falk
----------------------------------------------------	---------	------------	--------------