

# IEC 61850 Certificate - IEC 61850 Certificate #2282

## Siprotec 7SC805 Merging Unit [Siemens A.G., IC SG EA]

07/08/2021 04:32 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	74105994-OPE/INC 14-1572
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	81FE01606A5D72867EF50E718BE5F6 D8E3824A5CD8880FDE5D2505C90DB F2AFC
<b>61850 Edition:</b>	Edition 1	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Siemens A.G., IC SG EA	<b>Umbrella Organization:</b>	
<b>Address:</b>	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	Siprotec 7SC805 Merging Unit	<b>Serial Number:</b>	
<b>HW Version:</b>	7SC80542AB963FM0	<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	04.50	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Merging Unit	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	09/11/2015	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Time Activated Control:</b>	
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Test Document:</b>			

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:32 PM - Herbert Falk

- File 14-1572\_Siemens\_7SC805\_Certificate.pdf added

### Files

14-1572_Siemens_7SC805_Certificate.pdf	2.51 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------