

IEC 61850 Certificate - IEC 61850 Certificate #2286

GRL200 [Toshiba Corporation]

07/08/2021 04:32 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74106444-OPE/INC 14-3172
61850 Edition:	Edition 1	Certificate Hash:	0A9EE7E427855848BA4BE27B72F5FD CA4151C3F9C02539F9544ED0261C4E BB1F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Toshiba Corporation	Vendor Artifact Hash:	
Address:	Power Systems Protection and Control Fuchu Complex 1, Toshiba-Cho Fuchu-shi, Tokyo, 183-8511 Japan	Umbrella Organization:	
Product:	GRL200	Optional Reservation Test:	No
HW Version:	11-234-11-45-10-110	Serial Number:	
SW Version:	G2M850-01-E	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:32 PM - Herbert Falk

- File 14-3172_TOSHIBA_GRL200_ServerEd1_Certificate.pdf added

Files

14-3172_TOSHIBA_GRL200_ServerEd1_Certificate.pdf	3.07 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------