

IEC 61850 Certificate - IEC 61850 Certificate #2292

PRO-NVA 100X-T [Thytronic SpA]

07/08/2021 04:33 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 14 11 90467 001T
61850 Edition:	Edition 1	Certificate Hash:	A955190031467E6C697AB9199A22037 8EA8F513AA4029C64DA21612AE9F0F 3DF
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Thytronic SpA	Vendor Artifact Hash:	
Address:	Piazza Mistral 7 20139 Milano Italy	Umbrella Organization:	
Product:	PRO-NVA 100X-T	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.30	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:33 PM - Herbert Falk

- File 14-ZE 14 11 90467 001T-THYTRONIC_PRO-NVA100X-T_IEC61850Ed1-S added

Files

14-ZE 14 11 90467 001T-THYTRONIC_PRO-NVA100X-T_IEC61850Ed1-S.pdf 07/08/2021

Herbert Falk