

IEC 61850 Certificate - IEC 61850 Certificate #2305

PSL 6602U [Nanjing SAC Power Grid Automation Co., Ltd.]

07/08/2021 04:33 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74107091-OPE/INC 15-1467
61850 Edition:	Edition 1	Certificate Hash:	960E9BD6EA5FC623B7C4A6E61C5D7 0AD96D28AB1D11FE65F3A668E9C8D 2EDFF6
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Nanjing SAC Power Grid Automation Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 39 Shuige Road Jiangning Development Zone Nanjing 211153 China	Umbrella Organization:	
Product:	PSL 6602U	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	5.02.02.08g	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:33 PM - Herbert Falk

- File 15-1467_DNVGL_NanjingSACPowerGridAutomation_PSL6602U_ServerE added

Files

15-1467_DNVGL_NanjingSACPowerGridAutomation_PSL6602U_ServerE	199KB	07/08/2021	Herbert Falk
--	-------	------------	--------------