

IEC 61850 Certificate - IEC 61850 Certificate #2307

RTU194 [Controles S.A.]

07/08/2021 04:33 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	84000022-OPE/INC 15-1680
61850 Edition:	Edition 1	Certificate Hash:	4978EE5B3B07030D71A6BA236A1A5F 4213FD9BA5063585FAFA86198D8DAE C2D6
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Controles S.A.	Vendor Artifact Hash:	
Address:	Av. Rivera 3314 11300 Montevideo Uruguay	Umbrella Organization:	
Product:	RTU194	Optional Reservation Test:	No
HW Version:	F02-CP02-IA21-IB21-PA03-PB03-D02	Serial Number:	
SW Version:	4.32	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:33 PM - Herbert Falk

- File 15-1680_DNVGL_Conroles_RTU194_ServerEd1_Certificate.pdf added

Files

15-1680_DNVGL_Conroles_RTU194_ServerEd1_Certificate.pdf	1.79 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------