

IEC 61850 Certificate - IEC 61850 Certificate #2308

MICOM P746 [Schneider Electric Industries SAS]

07/08/2021 04:33 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: ZE 15 02 89191 001
61850 Tested Aspects:	Server	Certificate Hash: A08680A7EC84CC580BA98F1B44347D1D2F1992F3100FD2091B5A84250108CB9A
Company:	Schneider Electric Industries SAS	Vendor Artifact File Name:
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison France	Vendor Artifact Hash:
Product:	MICOM P746	Umbrella Organization: Schneider Electric
HW Version:		Optional Reservation Test: No
SW Version:	B1	Serial Number:
Key Words:	Protection	Publisher Legacy Variants:
Test Procedure Version:	2.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	09/12/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD Germany (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:33 PM - Herbert Falk

- File 15-ZE 15 02 89191 001-SchneiderElectric_P746-B1_IEC61850Ed1- added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

15-ZE 15 02 89191 001-SchneiderElectric_P746-B1_IEC61850Ed1.pdf, 25 MB

07/08/2021

Herbert Falk