

# IEC 61850 Certificate - IEC 61850 Certificate #2311

## SSP-510 [NARI Technology Co., Ltd.]

07/08/2021 04:34 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	ZE 15 05 80863 044
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	033C57B96F88FB0F3F46BC21A3290D 63A6BA4ABCE7AFA94158C600927B97 2C93
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	NARI Technology Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No. 19 Chengxin Avenue, 211106, 211106 Nanjing, Jiangsu People's Republic of China	<b>Umbrella Organization:</b>	
<b>Product:</b>	SSP-510	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	R1.21	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/12/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD Germany (A)		

**Description**  
This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:34 PM - Herbert Falk

- File 15-ZE 15 05 80863 044-NARI\_SSP-510\_IEC61850Ed1-Server-Certif added

### Files

15-ZE 15 05 80863 044-NARI_SSP-510_IEC61850Ed1-Server-Certif	218 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------