

IEC 61850 Certificate - IEC 61850 Certificate #2313

PDZ821-RTU [NARI Technology Co., Ltd.]

07/08/2021 04:34 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 15 05 80863 046
61850 Edition:	Edition 1	Certificate Hash:	B2E7A69B7AC1CECC44E0EE222BF18 6B189B7FF5C8ABF8EAF375CC73507A F0BF0
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NARI Technology Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 19 Chengxin Avenue, 211106 211106 Nanjing, Jiangsu People's Republic of China	Umbrella Organization:	
Product:	PDZ821-RTU	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:34 PM - Herbert Falk

- File 15-ZE 15 05 80863 046-NARI_PDZ821-RTU_IEC61850Ed1-Server-Cer added

Files

15-ZE 15 05 80863 046-NARI_PDZ821-RTU_IEC61850Ed1-Server-Certificate.pdf 07/08/2021

Herbert Falk