

# IEC 61850 Certificate - IEC 61850 Certificate #2317

## SYNCHROACT 5 [ABB Switzerland Ltd.]

07/08/2021 04:34 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	1KHL050022
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	3392DD9D8AFB9D8A6DCF1832F494F D5BDAECC7FD55C97828CC31D109B2 0CC726
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ABB Switzerland Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Synchronizing Equipment, Excitation Systems and Voltage Regulators Austrasse CH-5300 Turgi/Switzerland	<b>Umbrella Organization:</b>	
<b>Product:</b>	SYNCHROACT 5	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	2.1	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/12/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	ABB Switzerland Ltd. (B)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:34 PM - Herbert Falk

- File 1KHL050022SYNCHROACTIEC61850ConformanceCertificate.pdf added

### Files

1KHL050022SYNCHROACTIEC61850ConformanceCertificate.pdf	956 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------