

IEC 61850 Certificate - IEC 61850 Certificate #2320

PSL6602U [Nanjing SAC Power Grid Automation Co., Ltd.]

07/08/2021 04:34 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 1KHL050057
61850 Tested Aspects:	Server	Certificate Hash: 001162A68441742E2EFC2CF29CC4038FC633943302105263271E1930F303CFFF
Company:	Nanjing SAC Power Grid Automation Co., Ltd.	Vendor Artifact File Name:
Address:	No. 39 Shuige Road, Jiangning Development Zone Nanjing, China	Vendor Artifact Hash:
Product:	PSL6602U	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	5.02.02.08e	Serial Number:
Key Words:	Protection	Publisher Legacy Variants:
Test Procedure Version:	2.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	09/12/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	ABB Switzerland Ltd. (B)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:34 PM - Herbert Falk

- File 1KHL050057_PSL6602UIEC61850Ed1ConformanceCertificate.pdf added

Files

1KHL050057_PSL6602UIEC61850Ed1ConformanceCertificate.pdf	561 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------