

IEC 61850 Certificate - IEC 61850 Certificate #2323

Siprotec V4 7SJ64 [Siemens A.G., PTD EA D]

07/08/2021 04:34 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30430035-Consulting 2005-0260
61850 Edition:	Edition 1	Certificate Hash:	26AB50234D85F3BB048F4EB1C1CD4 DBE30D2F6522A7F5507013180623FFF 8565
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens A.G., PTD EA D	Vendor Artifact Hash:	
Address:	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	Umbrella Organization:	
Product:	Siprotec V4 7SJ64	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	4.60	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:34 PM - Herbert Falk

- File 2005-0260-Siemens-7SJ64-Certificate.pdf added

Files

2005-0260-Siemens-7SJ64-Certificate.pdf	739 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------