

IEC 61850 Certificate - IEC 61850 Certificate #2327

F60 Feeder Relay [GE Multilin]

07/08/2021 04:34 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30520014-Consulting 2005-0653
61850 Edition:	Edition 1	Certificate Hash:	666CDB28C819C76929B13F6E78DF7E DA946863F029E7A04CAFE091BFD6E C5265
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Multilin	Vendor Artifact Hash:	
Address:	215 Anderson Ave., Markham, ON Canada L6E 1B3	Umbrella Organization:	
Product:	F60 Feeder Relay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	4.61	Publisher Legacy Variants:	
Key Words:	Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:34 PM - Herbert Falk

- File 2005-0653-CertificateGEMultilinURF60.pdf added

Files

2005-0653-CertificateGEMultilinURF60.pdf	2.49 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------