

IEC 61850 Certificate - IEC 61850 Certificate #2329

SISTEAM 61850 Gateway ZY7060 [TEAM S.A.]

07/08/2021 04:34 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	535-Consulting 2006-0042
61850 Edition:	Edition 1	Certificate Hash:	E5C280833AF642542A4B262A40A54B6 7AFA5668B192D1565316C3F8935EDB F69
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	TEAM S.A.	Vendor Artifact Hash:	
Address:	Parque Tecnologico de Zamudio Edificio 108 E-48170 Zamudio (Vizcaya) Spain	Umbrella Organization:	
Product:	SISTEAM 61850 Gateway ZY7060	Optional Reservation Test:	No
HW Version:	ZY7060	Serial Number:	
SW Version:	ZY7082A	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:34 PM - Herbert Falk

- File 2006-0042-TEAM_ZY7060_Certificate.pdf added

Files

2006-0042-TEAM_ZY7060_Certificate.pdf	2.11 MB	07/08/2021	Herbert Falk
---------------------------------------	---------	------------	--------------