

# IEC 61850 Certificate - IEC 61850 Certificate #2331

## F650 Bay Controller [GE Multilin]

07/08/2021 04:35 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30620025-Consulting 2006-0298
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	321093394549C3BAEC2D5CDBE0EED 893A2836FBA22EAE005BE3B9836047 F6AB6
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Multilin	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Avda. Pinoa 10 48170 Zamudio Spain	<b>Umbrella Organization:</b>	
<b>Product:</b>	F650 Bay Controller	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	1	<b>Serial Number:</b>	
<b>SW Version:</b>	3.06 boot 4.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/12/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2006-0298-GE\_F650\_Certificate.pdf added

### Files

2006-0298-GE\_F650\_Certificate.pdf

2.11 MB

07/08/2021

Herbert Falk