

IEC 61850 Certificate - IEC 61850 Certificate #2332

MiCOM C264P [Areva T&D]

07/08/2021 04:35 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30620067-Consulting 2006-0308
61850 Edition:	Edition 1	Certificate Hash:	20D5228AA2728390AAC9C46D9F7E3E 9341ED73398AB1698C6D6F813664946 473
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Areva T&D	Vendor Artifact Hash:	
Address:	Protection & Control 34970 Lattes France	Umbrella Organization:	Schneider Electric
Product:	MiCOM C264P	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	4.31	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2006-0308-CertificateArevaC264P.pdf added

#2 - 07/09/2021 09:15 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

2006-0308-CertificateArevaC264P.pdf	2.17 MB	07/08/2021	Herbert Falk
-------------------------------------	---------	------------	--------------