

IEC 61850 Certificate - IEC 61850 Certificate #2335

Areva MiCOM P139 [Areva T&D]

07/08/2021 04:35 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30620085-Consulting 2006-0351
61850 Edition:	Edition 1	Certificate Hash:	68BFE28B9BF0D12C96F2E5F7C455B8 8C0C2CE8751DCAC5AA7002B06EDD4 80105
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Areva T&D	Vendor Artifact Hash:	
Address:	Lyoner Strasse 44-48 D-60528 Frankfurt am Main Germany	Umbrella Organization:	Schneider Electric
Product:	Areva MiCOM P139	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	612-206	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2006-0351-Certificate_Areva_TD_P139.pdf added

#2 - 07/09/2021 09:15 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

2006-0351-Certificate_Areva_TD_P139.pdf	1.98 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------