IEC 61850 Certificate - IEC 61850 Certificate #2344

Areva MiCOM P746 [Areva T&D UK Ltd.]

07/08/2021 04:35 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	50745.6746.801
61850 Tested Aspects:	Server	**Certificate Hash:**	3FC8E2D8A9A40D3E77B838E2212F659C214FCBEE3A920E8F7E5EFAF7C11D3C7D
Company:	Areva T&D UK Ltd.	**Vendor Artifact File Name:**	
Address:	St. Leonards Avenue Stafford, ST17 4LX United Kingdom	**Vendor Artifact Hash:**	
Product:	Areva MiCOM P746	**Umbrella Organization:**	
HW Version:	K	**Optional Reservation Test:**	No
SW Version:	03A	**Serial Number:**	
Key Words:	Protection	**Publisher Legacy Variants:**	
Test Procedure Version:	2.2	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	09/12/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	Grid Automation Laboratories (B)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 50745.6746.801_AREVA_P74603K_Certificate.pdf added

#2 - 08/04/2021 09:37 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6746.801_AREVA_P74603K_Certificate.pdf	296 KB	07/08/2021	Herbert Falk