IEC 61850 Certificate - IEC 61850 Certificate #2347

Areva MiCOM P545 [Areva T&D]

07/08/2021 04:35 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30620085-Consulting 2006-0443
61850 Tested Aspects:	Server	**Certificate Hash:**	69941B7644516288E8DE3F6759BFE3325508BB34E02EE865BDEA2B4F6AE0018C
Company:	Areva T&D	**Vendor Artifact File Name:**	
Address:	St. Leonards Avenue ST17 4LX Stafford United Kingdom	**Vendor Artifact Hash:**	
Product:	Areva MiCOM P545	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	51D	**Serial Number:**	
Key Words:	Differential, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	1.1	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	09/12/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2006-0443-Certificate_Areva_P545.pdf added

Files

2006-0443-Certificate_Areva_P545.pdf	297 KB	07/08/2021	Herbert Falk