

# IEC 61850 Certificate - IEC 61850 Certificate #2348

## GRZ100 [Toshiba Corporation]

07/08/2021 04:35 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30630021-Consulting 2006-0552
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	8B1E170C18BBC6DB960C4C7FD6696 2D73D6F9C563BC87A4935EEA929387 AAE0F
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Toshiba Corporation	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Power Systems Protection and Control Fuchu Complex 1, Toshiba-Cho Fuchu-Shi, Tokyo 183-8511 Japan	<b>Umbrella Organization:</b>	
<b>Product:</b>	GRZ100	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	GSPZM 1-01-A	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/12/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2006-0552-CertificateToshibaGRZ100.pdf added

### Files

2006-0552-CertificateToshibaGRZ100.pdf	2.17 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------