IEC 61850 Certificate - IEC 61850 Certificate #2351

UR F60 [GE Multilin]

07/08/2021 04:35 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30610052-Consulting 2006-0908
61850 Tested Aspects:	Server	**Certificate Hash:**	78C18BDC12CF7D8E6E60E5CB9DD8AC48715FB1F216526830C87751FB18B8A239
Company:	GE Multilin	**Vendor Artifact File Name:**	
Address:	215 Anderson Ave., Markham, ON Canada L6E 1B3	**Vendor Artifact Hash:**	
Product:	UR F60	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	5.20, Boot v3.01	**Serial Number:**	
Key Words:	Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	1.1	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	09/12/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2006-0908-CertificateGEURF60.pdf added

Files

2006-0908-CertificateGEURF60.pdf	2.17 MB	07/08/2021	Herbert Falk