

# IEC 61850 Certificate - IEC 61850 Certificate #2351

## UR F60 [GE Multilin]

07/08/2021 04:35 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30610052-Consulting 2006-0908
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	78C18BDC12CF7D8E6E60E5CB9DD8A C48715FB1F216526830C87751FB18B8 A239
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Multilin	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	215 Anderson Ave., Markham, ON Canada L6E 1B3	<b>Umbrella Organization:</b>	
<b>Product:</b>	UR F60	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	5.20, Boot v3.01	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/12/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2006-0908-CertificateGEURF60.pdf added

### Files

2006-0908-CertificateGEURF60.pdf	2.17 MB	07/08/2021	Herbert Falk
----------------------------------	---------	------------	--------------