

IEC 61850 Certificate - IEC 61850 Certificate #2352

SEL-311L [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:35 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30620245-Consulting 2006-1131
61850 Edition:	Edition 1	Certificate Hash:	F85D632C135C0F67C48F01DBBA304B FEF9AFBF4434381DC5D219561F4963 B1BE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2440 N.E. Hopkins Ct. Pullman, WA 99163 USA	Umbrella Organization:	
Product:	SEL-311L	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R403	Publisher Legacy Variants:	
Key Words:	Differential, Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	ABB Switzerland Ltd. (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2006-1131-SEL-311L-Certificate.pdf added

Files

2006-1131-SEL-311L-Certificate.pdf

2.06 MB

07/08/2021

Herbert Falk